

INSTALLATION REQUIREMENTS FOR WOOD FENCES AS PER THE FLORIDA BUILDING CODE

FINAL INSPECTION:

To be made after installation and completion of all elements of construction.

The following items will be reviewed at final inspection:

- Wood fences shall be constructed of decay and termite-resistant material as specified in Section 2304.12 of the Florida Building Code
- Wood fences shall be designed according to the loads as specified in Section 1616.2.1 and 2328 of the Florida Building Code
- Wood fences not exceeding six feet in height may be constructed to meet the following minimum requirements:
 1. Vertical post of nominal 4 x 4 to be spaced according to height of fence. (See detail below)
 2. Post shall be embedded 2'0" into a concrete footing 10" in diameter and 2'0" deep, Section 2328.2
 3. Horizontal framing shall consist of a minimum of 3 horizontal rails of nominal 2 x 4 material and shall be fastened according to Section 2324.3 of the Florida Building Code. Fences 4' or less will only require 2 horizontal rails.
 4. All fasteners shall be corrosion resistant as per Section 2324.2 of the Florida Building Code.

Land Development Code

As per Section 250128, all wooden fences shall have the recognizable finished side facing adjacent properties and right-of-ways.



Custom Wood




Spaced Picket



Shadowbox



Lattice Top





Fence Installation Requirements

BUILDING DEPARTMENT

Revision Date: 12/1/2022

Form I.D. Number: 030.1

SECTION 2224 HIGH VELOCITY HURRICANE ZONES – CHAIN LINK FENCES

§2224.1 Chain link fences in excess of 12 feet (3.7 m) in height shall be designed according to the loads specified in Chapter 16 (High Velocity Hurricane Zones).

§2224.2 Chain link fences less than 12 feet (3.7 m) in height shall be designed according to the loads specified in Chapter 16 (High Velocity Hurricane Zones) or may be constructed to meet the minimum requirements specified in Table 2224.

**TABLE 2224
CHAIN LINK FENCE MINIMUM REQUIREMENTS**

Fence Height (in feet)	Terminal Post Dimensions (o.d. x wall thickness) (in inches)	Line Post Dimensions (o.d. x wall thickness) (in inches)	Terminal Post Concrete Foundation Size (Diameter x Depth) (in inches)	Line Post Concrete Foundation Size (Diameter x Depth) (in inches)
Up to 4	2-3/8 x 0.042	1-5/8 x 0 .047	10 x 24	8 x 24
Over 4 to 5	2-3/8 x 0.042	1-7/8 x 0.055	10 x 24	8 x 24
Over 5 to 6	2-3/8 x 0.042	1-7/8 x 0 .065	10 x 24	8 x 24
Over 6 to 8	2-3/8 x 0 .110	2-3/8 x 0.095	10 x 36	10 x 36
Over 8 to 10	2-7/8 x 0. 110	2-3/8 x 0.130	12 x 40	10 x 40
Over 10 to 12	2-7/8 x 0.160	2-7/8 x 0 .120	12 x 42	12 x 42

ForSI: 1 inch = 25.4mm.

NOTES:

1. This Table is applicable only to fences with unrestricted airflow.
2. Fabric: 12-1/2 gage minimum.
3. Tension Bands: Use one less than the height of the fence in feet evenly spaced.
4. Fabric Ties: Must be minimum the same gage of the fabric.
5. Fabric Tie Spacing on the Top Rail: Five ties between posts, evenly spaced.
6. Fabric Tie Spacing on Line Posts: One less than height of the fence in feet, evenly spaced.
7. Either top rail or top tension wire shall be used.
8. Braces must be used at Terminal Posts if top tension wire is used instead of Top Rail.
9. Post Spacing: 10 foot (3 m) on center maximum.
10. Posts shall be embedded to within 6-inch (152 mm) from the bottom of the foundation.
11. In order to follow the contour of the land, the bottom of the fence may clear the contour of the ground by up to 5-inch (127 mm) without increasing table values to the next higher limit.

Other types of fences, (Aluminum, P.V.C., Chain Link with restricted air flow, etc...) must be DESIGNED to meet the Florida Building Code.